

# Broadband Outdoor Radiometer Calibration Shortwave Shade/Unshade

## BORCAL-SW 2018-01

Generated by



*Radiometer Calibration and Characterization*

### Calibration Facility

## Solar Radiation Research Laboratory

Latitude: 39.742°N

Longitude: 105.180°W

Elevation: 1828.8 meters AMSL

Time Zone: -7.0

Calibration date

04/11/2018

Report Date  
April 13, 2018



## **NOTICE**

This report was prepared as an account of work sponsored by an agency of the United States government. Neither the United States government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States government or any agency thereof.

# Broadband Outdoor Radiometer Calibration Report

## Table of contents

Introduction.....	3
Results summary.....	4
Appendix 1 Instrument Details.....	A1-1
Appendix 2 BORCAL Notes.....	A2-1
Appendix 3 Session Configuration Audit Report.....	A3-1
Appendix 4 Operator Logs.....	A4-1

# Introduction

This report compiles the calibration results from a Broadband Outdoor Radiometer Calibration (BORCAL). The work was accomplished at the Radiometer Calibration Facility shown on the front of this report. The calibration results reported here are traceable to the International System (SI) Units of Measurement.

This report includes these sections:

- Results Summary - a table of all instruments included in this report summarizing their calibration results and uncertainty.
- Instrument Details - the calibration certificates for each instrument.
- Environmental and Sky Conditions - meteorological conditions and reference irradiance during the calibration event.

# Results Summary

**Table 1. Results Summary**

Instrument	Customer	R@45 <sup>1</sup> ( $\mu\text{V}/\text{W}/\text{m}^2$ )	U <sup>2</sup> (%)	Rnet <sup>3</sup> ( $\mu\text{V}/\text{W}/\text{m}^2$ )	Page
2530	NREL-SRRL-BMS	11.038	$\pm 1.1$	N/A	A1-2
2541	NREL-RCC	9.6314	$\pm 1.4$	N/A	A1-4

<sup>1</sup> CF = 1000 / R

<sup>2</sup> See certificate for valid zenith angle range

<sup>3</sup> Instrument's Effective Net IR Response

Note: Environmental Conditions for BORCAL starts on page A1-6.

# Appendix 1

## Instrument Details

Calibration Certificates: 2 pages for each radiometer (3 including Environmental Conditions)

Environmental Conditions for BORCAL: Last Page of a Calibration Certificate. Note: This appears only once, at the end of Appendix 1.



# National Renewable Energy Laboratory

## Solar Radiation Research Laboratory

### Metrology Laboratory

### Calibration Certificate

**Test Instrument:** Pyranometer  
**Manufacturer:** Hukseflux  
**Model:** SR25  
**Serial Number:** 2530  
**Calibration Date:** 4/11/2018  
**Due Date:** 4/11/2019  
**Customer:** NREL-SRRL-BMS  
**Environmental Conditions:** see page 3  
**Test Dates:** 4/11

This certifies that the above product was calibrated in compliance with procedure listed below. Measurement uncertainties at the time of calibration are consistent with the Guide to the Expression of Uncertainty in Measurement (GUM) using Reda et al., 2008. All nominal values are traceable to the International System (SI) Units of Measurement.

No statement of compliance with specifications is made or implied on this certificate. However, the estimated uncertainties are the uncertainties of the calibration process; users must add other uncertainties that are relevant to their measuring system, environmental and sky conditions, outdoor set-up, and site location.

This certificate applies only to the item identified above and shall not be reproduced other than in full, without specific written approval from the calibration facility. Certificate without signature is not valid.

**Table 1. Traceability**

Measurement Type	Instrument	Calibration Date	Calibration Due Date
Beam Irradiance †	Eppley Absolute Cavity Radiometer Model HF, S/N 29219	09/25/2017	09/25/2018
Data Acquisition	NREL Data Acquisition System Model RAP-DAQ, S/N 2005-998	04/12/2017	04/12/2019
Data Acquisition	NREL Data Acquisition System Model RAP-DAQ, S/N 2005-999	04/12/2017	04/12/2019

† Through the World Radiometric Reference (WRR)

**Number of pages of certificate:** 3

**Calibration Procedure:** NREL/TP-1900-68999; <http://www.nrel.gov/docs/fy17osti/68999.pdf>

**Setup:** Radiometers are calibrated outdoors, using the sun as the source. Pyranometers and pyrgeometers are installed for horizontal measurements, with their signal connectors oriented north, if their design permits.

**Calibrated by:** RCC

-----  
Ibrahim Reda, Technical Manager

-----  
Date

For questions or comments, please contact the technical manager at:  
[ibrahim.reda@nrel.gov](mailto:ibrahim.reda@nrel.gov); 303-384-6385; 15013 Denver West Parkway, Golden, CO 80401, USA

# Calibration Results

## 2530 Hukseflux SR25

The responsivity ( $R$ ,  $\mu\text{V}/\text{W}/\text{m}^2$ ) of the test instrument during calibration is calculated using this Measurement Equation:


$$R = (Vu - Vs) / N * \text{COS}(Z) \tag{1}$$

where,


$Vu$  = radiometer unshaded output voltage (microvolts),  
 $Vs$  = radiometer shaded output voltage (microvolts),

$N$  = reference direct irradiance ( $\text{W}/\text{m}^2$ ),  
 $Z$  = zenith angle (degrees).

**Figure 1. Average Responsivity vs Zenith Angle**




**Figure 2. Shaded Voltage Ratio (Test/Control) vs Zenith Angle**



**Table 2. Calibration Result and Uncertainty**

R @ 45° ( $\mu\text{V}/\text{W}/\text{m}^2$ )	11.038
Type-B Standard Uncertainty, $u(B)$ (%)	$\pm 0.30$
Type-A Standard Uncertainty, $u(A)$ (%)	$\pm 0.072$
Standard Uncertainty of range, $u(R)$ (%)	$\pm 0.45$
Std. Uncertainty of sensor non-linearity, $u(NL)$ (%)	$\pm 0.12$
Effective degrees of freedom, $DF(c)$	+Inf
Coverage factor, $k$	1.96
Expanded Uncertainty, $U95$ (%)	$\pm 1.1$
Thermal Offset ( $\text{W}/\text{m}^2$ )	0.5
Valid zenith angle range	31.4° to 61.7°

**Figure 3. History of instrument at Zenith Angle = 45°**



### References:

- [1] Reda, I.; Andreas A. (2017). Calibration Procedure of a Modified Hukseflux SR25 as an Example to Establish the Diffuse Reference for the Broadband Outdoor Radiometer Calibration; NREL/TP-1900-68999; <http://www.nrel.gov/docs/fy17osti/68999.pdf>.
- [2] Reda, I.; Stoffel, T.; Myers, D. (2003). "Method to Calibrate a Solar Pyranometer for Measuring Reference Diffuse Irradiance." Solar Energy. Vol. 74, 2003; pp. 103-112; NREL Report No. JA-560-35025. doi:10.1016/S0038-092X(03)00124-5





# National Renewable Energy Laboratory

## Solar Radiation Research Laboratory

### Metrology Laboratory

### Calibration Certificate

**Test Instrument:** Pyranometer  
**Manufacturer:** Hukseflux  
**Model:** SR25  
**Serial Number:** 2541  
**Calibration Date:** 4/11/2018  
**Due Date:** 4/11/2019  
**Customer:** NREL-RCC  
**Environmental Conditions:** see page 3  
**Test Dates:** 4/11

This certifies that the above product was calibrated in compliance with procedure listed below. Measurement uncertainties at the time of calibration are consistent with the Guide to the Expression of Uncertainty in Measurement (GUM) using Reda et al., 2008. All nominal values are traceable to the International System (SI) Units of Measurement.

No statement of compliance with specifications is made or implied on this certificate. However, the estimated uncertainties are the uncertainties of the calibration process; users must add other uncertainties that are relevant to their measuring system, environmental and sky conditions, outdoor set-up, and site location.

This certificate applies only to the item identified above and shall not be reproduced other than in full, without specific written approval from the calibration facility. Certificate without signature is not valid.

**Table 1. Traceability**

Measurement Type	Instrument	Calibration Date	Calibration Due Date
Beam Irradiance †	Eppley Absolute Cavity Radiometer Model HF, S/N 29219	09/25/2017	09/25/2018
Data Acquisition	NREL Data Acquisition System Model RAP-DAQ, S/N 2005-998	04/12/2017	04/12/2019
Data Acquisition	NREL Data Acquisition System Model RAP-DAQ, S/N 2005-999	04/12/2017	04/12/2019

† Through the World Radiometric Reference (WRR)

**Number of pages of certificate:** 3

**Calibration Procedure:** NREL/TP-1900-68999; <http://www.nrel.gov/docs/fy17osti/68999.pdf>

**Setup:** Radiometers are calibrated outdoors, using the sun as the source. Pyranometers and pyrgeometers are installed for horizontal measurements, with their signal connectors oriented north, if their design permits.

**Calibrated by:** RCC

-----  
Ibrahim Reda, Technical Manager

-----  
Date

For questions or comments, please contact the technical manager at:  
[ibrahim.reda@nrel.gov](mailto:ibrahim.reda@nrel.gov); 303-384-6385; 15013 Denver West Parkway, Golden, CO 80401, USA

# Calibration Results

## 2541 Hukseflux SR25

The responsivity ( $R$ ,  $\mu\text{V}/\text{W}/\text{m}^2$ ) of the test instrument during calibration is calculated using this Measurement Equation:


$$R = (Vu - Vs) / N * \text{COS}(Z) \tag{1}$$

where,


$Vu$  = radiometer unshaded output voltage (microvolts),  
 $Vs$  = radiometer shaded output voltage (microvolts),

$N$  = reference direct irradiance ( $\text{W}/\text{m}^2$ ),  
 $Z$  = zenith angle (degrees).

**Figure 1. Average Responsivity vs Zenith Angle**




**Figure 2. Shaded Voltage Ratio (Test/Control) vs Zenith Angle**



**Table 2. Calibration Result and Uncertainty**

R @ 45° ( $\mu\text{V}/\text{W}/\text{m}^2$ )	9.6314
Type-B Standard Uncertainty, $u(B)$ (%)	$\pm 0.30$
Type-A Standard Uncertainty, $u(A)$ (%)	$\pm 0.063$
Standard Uncertainty of range, $u(R)$ (%)	$\pm 0.66$
Std. Uncertainty of sensor non-linearity, $u(NL)$ (%)	$\pm 0.12$
Effective degrees of freedom, $DF(c)$	+Inf
Coverage factor, $k$	1.96
Expanded Uncertainty, $U95$ (%)	$\pm 1.4$
Thermal Offset ( $\text{W}/\text{m}^2$ )	0.5
Valid zenith angle range	31.4° to 61.7°

**Figure 3. History of instrument at Zenith Angle = 45°**



### References:

- [1] Reda, I.; Andreas A. (2017). Calibration Procedure of a Modified Hukseflux SR25 as an Example to Establish the Diffuse Reference for the Broadband Outdoor Radiometer Calibration; NREL/TP-1900-68999; <http://www.nrel.gov/docs/fy17osti/68999.pdf>.
- [2] Reda, I.; Stoffel, T.; Myers, D. (2003). "Method to Calibrate a Solar Pyranometer for Measuring Reference Diffuse Irradiance." Solar Energy. Vol. 74, 2003; pp. 103-112; NREL Report No. JA-560-35025. doi:10.1016/S0038-092X(03)00124-5

# Environmental and Sky Conditions for BORCAL-SW 2018-01

Calibration Facility: Solar Radiation Research Laboratory

Latitude: 39.742°N


Longitude: 105.180°W

Elevation: 1828.8 meters AMSL

Time Zone: -7.0

## Reference Irradiance:

Figure 4. Reference Irradiance



## Meteorological Observations:

Figure 5. Temperature




Figure 6. Humidity




Figure 7. Pressure




Figure 8. Estimated Broadband Aerosol Optical Depth




Table 3. Meteorological Observations

Observations	Mean	Min	Max
Temperature (°C)	22.36	20.88	23.18
Humidity (%)	11.33	9.35	13.86
Pressure (mBar)	808.7	807.9	809.4
Est. Aerosol Optical Depth (BB)	0.046	0.036	0.054

For other information about the calibration facility visit: [http://www.nrel.gov/solar\\_radiation/](http://www.nrel.gov/solar_radiation/)

# Appendix 2

## BORCAL Notes

Instrument, Configuration, and Session Notes for the BORCAL

# BORCAL Notes

---

Facility: Solar Radiation Research Laboratory

Comments:

Avg. Station Pressure & Temperature is for Denver, CO, which is used for the Solar Position Algorithm (SPA).

---

Operator: RCC

Comments:

Un-attended with no operator

# Appendix 3

## Session Configuration Audit Report

Latest Session Configuration Audit Report for the BORCAL

### BORCAL 2018-01 Session Configuration Audit Report

LOCATION									
Facility	Facility Abbrev.	Contact	Latitude	Longitude	Elevation (m)	Avg press (mbr)	Avg temp (C)	Time zone	ISO
Solar Radiation Research Laboratory	SRRL	Afshin M. Andreas	39.742	-105.180	1828.8	835.0	10.0	-7.0	

SYSTEM				ASR RADIOMETERS			
<b>% Error Thresholds</b> Cav1 / Cav2 <input type="text" value="1.0"/> Dif1 / Dif2 <input type="text" value="7.0"/> Global Ctrl / Ref <input type="text" value="5.0"/> Direct Ctrl / Ref <input type="text" value="5.0"/> Test(x) / Test(x-1) <input type="text" value="3.0"/>		<b>Scan Rate (sec)</b> Radiometers <input type="text" value="10"/> Meteorological <input type="text" value="180"/>		<b>Clock</b> Reset Interval (m) <input type="text" value="0"/> Warning Threshold (s) <input type="text" value="1"/> Delta UT1 <input type="text" value="0.100"/>		Channel Junction Box Cable Location <b>ASR 1: 140310 Kipp &amp; Zonen SP-LITE2</b> 26 08-02 Tbl-00- <b>ASR 2: None</b>	
<b>Delta Thresholds</b> Temp(x) - Temp(x-1) <input type="text" value="3.0"/> Hum(x) - Hum(x-1) <input type="text" value="10.0"/> Bar(x) - Bar(x-1) <input type="text" value="2.0"/> Thm(x) - Thm(x-1) <input type="text" value="2.0"/> Thm (Dome-Case) <input type="text" value="3.0"/> Case Thm (Inst-Pyrg) <input type="text" value="5.0"/>		<b>ASR Setup</b> Scan Rate (s) <input type="text" value="1"/> ASR Readings <input type="text" value="2"/> Threshold 1 (Blue) <input type="text" value="1.000"/> Threshold 2 (Green) <input type="text" value="2.000"/> Threshold 3 (Brown) <input type="text" value="3.000"/> Diffuse scaling factor <input type="text" value="0.25"/>		<b>Uncertainty</b> Zenith Angle (deg) <input type="text" value="0.003"/> Significant Figures <input type="text" value="2"/> 45° Offsets: - <input type="text" value="15.00"/> + <input type="text" value="15.00"/> Min. Legal Direct <input type="text" value="700"/> Max. Legal Diffuse <input type="text" value="180"/> Max. Diffuse/Direct (%) <input type="text" value="45.0"/>		<b>METEOROLOGICAL INSTRUMENTS</b> Channel Junction Box Cable Location <b>Temperature: E1220001-T Vaisala HMP155-T</b> 121 05-01 22-10 Deck Scale <input type="text" value="100"/> Offset <input type="text" value="-40"/> <b>Humidity: E1220001-H Vaisala HMP155-H</b> 122 05-02 22-11 Deck Scale <input type="text" value="100"/> Offset <input type="text" value="0"/> <b>Barometer: Y0550020 Vaisala PTB101B</b> 120 05-00 Datalab Scale <input type="text" value="184"/> Offset <input type="text" value="600"/>	
<b>Shade/Unshade</b> <input checked="" type="checkbox"/> Enabled Port <input type="text" value="2"/> Shaded Wait (s) <input type="text" value="85"/> Unshaded Wait (s) <input type="text" value="15"/>		<b>Miscellaneous</b> PW: Slope <input type="text" value="1.83"/> Intercept <input type="text" value="1.00"/> Tilt: Zenith <input type="text" value="0.00"/> Azimuth <input type="text" value="0.00"/> W in: Min <input type="text" value="150"/> Max <input type="text" value="450"/> Zenith Angle (Auto Mode): Startup <input type="text" value="70"/> Shutdown <input type="text" value="70"/> Intervals (m): Cavity Calibration <input type="text" value="60"/> Oper. Log <input type="text" value="120"/> SPA: Atmos. Refraction <input type="text" value="0.5667"/> Delta T <input type="text" value="69.084"/>		<b>GPS TIME RECIEVER</b> <b>GPS: None</b> Type Port Baud Parity Stop bits Data bits <input type="text" value=""/> <input type="text" value="0"/> <input type="text" value="0"/> <input type="text" value="0"/> <input type="text" value="0"/> <input type="text" value="0"/>			

DATALOGGER											
Logger/Relay		DMM		Communications							
Unit 0	2005-998 NREL RAP-DAQ	SG42000600	Agilent 34420A								
Unit 1	2005-999 NREL RAP-DAQ	SG42000530	Agilent 34420A								
Unit 0	None	None									
Unit 0	None	None									
		Unit 0	Unit 0								
	Cal Date	04/12/2017	04/12/2017								
	Cal Due Date	04/12/2019	04/12/2019								
<b>System Offsets:</b>	Volts DC (µV)	2.44	2.44	0.00	0.00						
	2-Wire Res. (mOhms)	3640.00	3640.00	0.00	0.00						
	4-Wire Res. (mOhms)	0.06	0.06	0.00	0.00						
				DMM	Unit	Type	Addr.	Board	Parity	Stop	Data
				Relay	0	GPIB	21	0	0	0	0
				DMM	1	GPIB	22	0	0	0	0
				Relay	1	GPIB	25	1	0	0	0
					-1		0	0	0	0	0
					-1		0	0	0	0	0
					-1		0	0	0	0	0
					-1		0	0	0	0	0

CAVITIES, CONTROL UNITS, AND DIGITAL MULTI METERS											
<b>Cavity 1</b> Unwindowed WRR <input type="text" value="1.000000"/> Windowed WRR <input type="text" value="1.061520"/> Unwindowed Uncert (%) <input type="text" value="0.40"/> Windowed Uncert (%) <input type="text" value="0.40"/> Heater Resistance <input type="text" value="153.40"/> Heater Lead Resistance <input type="text" value="0.0660"/> Mfg Calibration Factor <input type="text" value="2.00090"/> Default Sensitivity <input type="text" value="0.01051"/> Cal Date <input type="text" value="09/25/2017"/> Cal Due Date <input type="text" value="09/25/2018"/>		<b>Cavity 2</b> Unwindowed WRR <input type="text" value="0.000000"/> Windowed WRR <input type="text" value="0.000000"/> Unwindowed Uncert (%) <input type="text" value="0.00"/> Windowed Uncert (%) <input type="text" value="0.00"/> Heater Resistance <input type="text" value="0.00"/> Heater Lead Resistance <input type="text" value="0.00000"/> Mfg Calibration Factor <input type="text" value="0.00000"/> Default Sensitivity <input type="text" value="0.00000"/> Cal Date <input type="text" value=""/> Cal Due Date <input type="text" value=""/>		<b>Unit 1</b> Cavity Head <input type="text" value="29219 Eppley HF"/> Control Unit <input type="text" value="03691C NREL Reda"/> Digital Multi Meter <input type="text" value="MY44040325 Hewlett Packard 34970A"/> Cavity Location <input type="text" value="South Patio"/>		<b>Unit 2</b> Cavity Head <input type="text" value="None"/> Control Unit <input type="text" value="None"/> Digital Multi Meter <input type="text" value="None"/> Cavity Location <input type="text" value=""/>					
<b>Calibration Waits (Seconds)</b> TP-solar <input type="text" value="0"/> <input type="text" value="0"/> TP-heated <input type="text" value="40"/> <input type="text" value="0"/> TP-zero <input type="text" value="60"/> <input type="text" value="0"/> Dwell <input type="text" value="0"/> <input type="text" value="0"/> Active <input checked="" type="checkbox"/> <input type="checkbox"/> Window in Use <input checked="" type="checkbox"/> <input type="checkbox"/>		<b>Control Unit 1</b> Current Shunt <input type="text" value="1.000"/> <input type="text" value="0.000"/> Circuit Resist <input type="text" value="2.600"/> <input type="text" value="0.000"/> Cal Date <input type="text" value="09/26/2016"/> Cal Due Date <input type="text" value="09/26/2017"/>		<b>Control Unit 2</b> Current Shunt <input type="text" value=""/> Circuit Resist <input type="text" value=""/> Cal Date <input type="text" value=""/> Cal Due Date <input type="text" value=""/>							
<b>Communications</b> Type Port Bd. Parity Stop bits Data bits <b>Control Unit 1</b> GPIB 19 0 0 0 0 <b>DMM 1</b> 0 0 0 0 0 <b>Control Unit 2</b> 0 0 0 0 0 <b>DMM 2</b> 0 0 0 0 0											

### BORCAL 2018-01 Session Configuration Audit Report

#### DIFFUSE REFERENCE INSTRUMENTS

Responsivity	Cal Date	Cal Due Date	Shading Disk			Uncertainty		Max Out (mV)	Channel	J Box	Cable	Location	Tilt	Active
			Diameter (cm)	Arm Length (cm)	Subtended Angle	Percent	Offset (W/m <sup>2</sup> )							
<b>Diffuse 1: 2529 Hukseflux SR25</b>														
9.253	05/04/2017	05/04/2018	6.2	70.3	5.0	1.50	0.0	25	116	15-08	04-07	BMS Tracker	<input type="checkbox"/>	<input checked="" type="checkbox"/>
Diffuse 1: Case 10K Temperature									n/a	n/a	n/a			
Diffuse 1: Dome 10K Temperature									n/a	n/a	n/a			

#### PYRGEOMETER INSTRUMENTS

Cal Date	Cal Due Date	K0	Calibration Coefficients				K <sub>r</sub>	Uncert. (W/m <sup>2</sup> )	Max Out (mV)	Channel	J Box	Cable	Location	Active
			K1	K2	K3	K <sub>r</sub>								
<b>Pyrgometer 1: None</b>														
		0.00000	0.00000	0.00000	0.00000	0.00000E+0	0.00	0					<input type="checkbox"/>	
Pyrgometer 1: Case Thermistor									n/a	n/a	n/a			
Pyrgometer 1: Dome Thermistor									n/a	n/a	n/a			



**BORCAL 2018-01 Session Configuration Audit Report****INSTRUMENT GROUPS**

Group	Calib. Type	Out (mV)	Instrument Type	Instrument Grouping Type	Correcting Pyrgeometer	Count
1	Global	25	Hukseflux SR25	Hukseflux SR25	none	2
Total						2

### BORCAL 2018-01 Session Configuration Audit Report

#### INSTRUMENTS

Serial Number	Model	Customer	Grp	Idx	Ch	Box	Cbl	ISO	AIM	Vent	Use	Location	Due
2530	SR25	NREL-SRRL-BMS	1	1	14	07-02		Yes	Yes	No	TOT	Tkr-07-	12
2541	SR25	NREL-RCC	1	2	15	07-03		Yes	Yes	No	TOT	Tkr-07-	12

# Appendix 4

## Operator Session Logs

Operator session logs for the BORCAL

## BORCAL 2018-01 Operator Session Log

=====  
 Session: 1

Date	Start Time	End Time	Cavity S/N	Setup	M (beg)	M (end)
04-10-2018	10:48:21	11:49:58	29219	7:00	959.1	957.4

Observations:

Time	Zenith	ASR	Direct	% Diffuse	Operator
11:09:05	33.76	Brown	988.3	14.9	Afshin Andreas

Comments:

Test of new SW SUN mode. Sky is poor.

Time	Zenith	ASR	Direct	% Diffuse	Operator
11:30:31	32.39	Green	985.6	15.2	Afshin Andreas

Comments: [None]

=====  
 Session: 2

Date	Start Time	End Time	Cavity S/N	Setup	M (beg)	M (end)
04-10-2018	11:49:58	12:51:39	29219	7:00	957.4	956.9

Observations:

Time	Zenith	ASR	Direct	% Diffuse	Operator
12:06:35	31.60	Red	868.4	24.2	Afshin Andreas

Comments: [None]

=====  
 Session: 3

Date	Start Time	End Time	Cavity S/N	Setup	M (beg)	M (end)
04-10-2018	12:51:39	13:04:53	29219	7:00	956.9	956.9

Observations:

Time	Zenith	ASR	Direct	% Diffuse	Operator
13:03:12	34.41	Red	236.6	67.5	Afshin Andreas

Comments: [None]

=====  
 Session: 4

Date	Start Time	End Time	Cavity S/N	Setup	M (beg)	M (end)
04-10-2018	13:05:18	13:36:48	29219	7:00	956.9	956.9

Observations: [None]

=====  
 Session: 5

Date	Start Time	End Time	Cavity S/N	Setup	M (beg)	M (end)
04-11-2018	08:58:56	09:59:38	29219	0:00	956.1	956.4

Observations: [None]

=====  
 Session: 6

Date	Start Time	End Time	Cavity S/N	Setup	M (beg)	M (end)
04-11-2018	09:59:38	11:00:45	29219	0:00	956.4	956.2

Observations: [None]

=====  
 Session: 7

Date	Start Time	End Time	Cavity S/N	Setup	M (beg)	M (end)
04-11-2018	11:00:45	12:02:26	29219	0:00	956.2	956.2

# BORCAL 2018-01 Operator Session Log

Observations: [None]

=====  
Session: 8

-----  
Date            Start Time      End Time        Cavity S/N     Setup           M (beg)        M (end)  
04-11-2018     12:02:26      13:04:10      29219          0:00           956.2         955.8  
-----

Observations: [None]

=====  
Session: 9

-----  
Date            Start Time      End Time        Cavity S/N     Setup           M (beg)        M (end)  
04-11-2018     13:04:10      14:05:24      29219          0:00           955.8         955.8  
-----

Observations: [None]

=====  
Session: 10

-----  
Date            Start Time      End Time        Cavity S/N     Setup           M (beg)        M (end)  
04-11-2018     14:05:24      15:06:11      29219          0:00           955.8         955.6  
-----

Observations: [None]

=====  
Session: 11

-----  
Date            Start Time      End Time        Cavity S/N     Setup           M (beg)        M (end)  
04-11-2018     15:06:11      16:07:29      29219          0:00           955.6         955.6  
-----

Observations: [None]

=====  
Session: 12

-----  
Date            Start Time      End Time        Cavity S/N     Setup           M (beg)        M (end)  
04-11-2018     16:07:29      16:18:10      29219          0:00           955.6         955.6  
-----

Observations: [None]

=====  
Session: 13

-----  
Date            Start Time      End Time        Cavity S/N     Setup           M (beg)        M (end)  
04-12-2018     07:46:07      08:47:11      29219          0:00           956.0         958.1  
-----

Observations: [None]

=====  
Session: 14

-----  
Date            Start Time      End Time        Cavity S/N     Setup           M (beg)        M (end)  
04-12-2018     08:47:11      09:47:46      29219          0:00           958.1         959.0  
-----

Observations: [None]

=====  
Session: 15

-----  
Date            Start Time      End Time        Cavity S/N     Setup           M (beg)        M (end)  
04-12-2018     09:47:46      10:48:50      29219          0:00           959.0         958.5  
-----

Observations: [None]

=====  
Session: 16

-----  
Date            Start Time      End Time        Cavity S/N     Setup           M (beg)        M (end)  
04-12-2018     10:48:50      11:50:30      29219          0:00           958.5         957.9  
-----

Observations: [None]

=====  
Session: 17

-----  
Date            Start Time      End Time        Cavity S/N     Setup           M (beg)        M (end)  
04-12-2018     11:50:30      12:52:20      29219          0:00           957.9         957.4  
-----

## BORCAL 2018-01 Operator Session Log

Observations: [None]

=====  
Session: 18

-----  
Date            Start Time      End Time        Cavity S/N     Setup            M (beg)        M (end)  
04-12-2018     12:52:20       13:53:43       29219           0:00            957.4           956.4  
-----

Observations: [None]

=====  
Session: 19

-----  
Date            Start Time      End Time        Cavity S/N     Setup            M (beg)        M (end)  
04-12-2018     13:53:43       14:54:42       29219           0:00            956.4           955.7  
-----

Observations: [None]

=====  
Session: 20

-----  
Date            Start Time      End Time        Cavity S/N     Setup            M (beg)        M (end)  
04-12-2018     14:54:42       15:37:54       29219           0:00            955.7           955.7  
-----

Observations: [None]